

DRINKING WATER & SANITATION DIVISION, KHUNTI

District water Testing Report Laboratory

Water Test Report

Ref. NO.

CUSTOMER NAME:- D.A.V. School, Khunti

Block Khunti

G.P:- N.P

Village:- N.P

Date:- 10/05/2022

Source of the Sample:- Bore well

Tola:- Khos

Sample Collected by:- Lab Representative

Physical Location:-

Sl. NO.	Tested Parameters	Unit	Bis Desirable Limit	Bis Permissible Limit	Actual Level
1	IRON	Mg/L	0.3	1.0	0.14
2	FLURIDE	Mg/L	1.0	1.5	—
3	CHLORIDE	Mg/L	250	1000	100
4	T.D.S	Mg/L	500	2000	266
5	ALKALINITY	Mg/L	200	600	60
6	TURBIDITY	NTU	1.0	5.0	—
7	HARDNESS	Mg/L	300	600	102
8	ph		6.5	8.5	—
9	NITRATE	Mg/L	45	45	—

REMARKS:- As per Above parameters Analysed, the water sample is Accepted for Drinking purpose.

By
10/05/2022
CHEMIST

District Water testing
Laboratory, Khunti

for
10/05/22
J.E

District Water testing
Laboratory, Khunti

for
10/05/22
A.E

DW&SD, Khunti
Sub Division Urban, Khunti

Principal

S.S.D.A.V. Centenary Public School
Khunti (Jharkhand) 835210
C.B.E. Affin. No. 3430165
No - 08928-220676

MANAGER
S.S.D.A.V. Centenary Public
School, Khunti-835210
Ph. No. 06528-220676